

**MEMORANDUM**

**Date:** October 31, 2005

**To:** Environmental Health Managers  
District Health Directors  
Virginia Tech Contract Soil Scientists  
Authorized Onsite Soil Evaluators

**GMP #129**

**From:** E. Thomas Joy, PE, Technical Services Engineer  
Division of Onsite Sewage and Water Services

**Subject:** Approval of SEPTECH™ Septic Tanks Models ST-750, ST-1060,  
ST-1250, ST-1500 for use in Virginia when used with effluent filters

**Approval:** The subject tanks do not meet the criteria of 12 VAC 5- 610-815. However, after reviewing the data provided by FRALO Plastech Manufacturing, LLC, the Division of Onsite Sewage and Water Services approves the tanks for use in Virginia if an NSF certified effluent filter is attached to the outlet structure of each tank.